

AMENDMENT TO BID NO. GEM/2024/B/5192289

Subject: Reply to Pre-Bid Queries for Supply, Installation and commissioning of Out Door LED Video Wall and modifications to the bid documents.

Kindly refer to the Pre-Bid queries received through email against CSIR HQ GEM Tender No. GEM/2024/B/5192289 dated 23-07-2024.

The replies to the Pre-bid query from the participating firms and modifications are as follows :

Company Name – M/s. Vectra Digi Technologies			
S. No.	Detail's as per tender	Modification Suggested	Remarks
1.	Item No. 1 (a) Serial No. 2 LED Pixel Pitch P7	LED Pixel Pitch P4	The Screen is being mounted on the roof of Security Room and the height of the LED would be approx. 8-10 feet from the terrace of the Security Room. The Screen will be viewed form the Road and hence visibility distance is ok. Clause remains same.
2.	Item No. 1 (a) Serial No. 11 Die cast Aluminum Cabinet	Mild Steel Cabinets	Mild Steel cabinet will be heavier and prone to corrosion. Die Cast cabinets are Rust free. Clause remains same.
3.	Pole Height elevation not specified	2-3 Ft. Height Elevation to be specified.	Pole height elevation would be 2 to 3 feet and is considered as the revised specification.
4.	Item No. 1 (a) Serial No. 21 IP65 mentioned in the specifications	ACP Cladding Covering of LED Display	If the screen is covered with the ACP Cladding, it will generate more heat. Clause remains same.



5.	Scope of Work	All communication and Network wiring including Electrical Wiring is under bidder scope of work.	1. Included in the scope of work. 2. All communication and Network wiring including Electrical Wiring is under bidder scope of work
----	---------------	---	--

Company Name – M/s. IGATE Global Solution & Traders

S. No.	Detail's as per tender	Modification Suggested	Remarks
1.	Item No. 1 (a) Serial No. 22 CE, FCC, BIS Certifications are mandatory	Need to remove certification from LED Wall specifications	Standard specifications Clause remains same.
2.	Item No. 1 (b) Serial No. 4 LED Controller Operating Temperature 0 -55 degree specified	Operating temperature to be modified as 0-40 degree	Clause remains same.
3.	Item No. 1 (b) Serial No. 6 LED Controller Certifications BIS Specified	To add IEC, UL Certifications	Agreed Clause may be read as IEC, UL, BIS Certifications.

Company Name – M/s. Kan Universal

S. No.	Detail's as per tender	Modification Suggested	Remarks
1.	Pole Height elevation not specified	2-3 Ft. Height Elevation to be specified.	Pole height elevation would be 2 to 3 feet and is considered as the revised specification.

Company Name – M/s. LG Electronics

S. No.	Detail's as per tender	Modification Suggested	Remarks
1.	Item No. 1 (a) Serial No. 22 CE, FCC, BIS Certifications are mandatory	Need to remove certification from LED Wall Specifications	Standard specifications Clause remains same.
2.	Item No. 1 (b) Serial No. 4 LED Controller Operating	Operating temperature to be modified as 0-40 degree	Clause remains same.

RG
NOT 21

	Temperature 0 -55 degree specified		
3.	Item No. 1 (b) Serial No. 6 LED Controller Certifications BIS Specified	To add IEC, UL, BIS Certifications	Agreed. Clause may be read as IEC, UL, BIS Certifications.


In addition to above, the following item and terms are also be added in the tender specification for installation of the outdoor LED Display.

ADDITIONAL SPECIFICATIONS AND ADDENDUM TO THE BID NO. GEM/2024/B/5192289 FOR INSTALLATION OF THE OUTDOOR LED DISPLAY

1. STRUCTURE FOR INSTALLATION IN THE SCOPE OF THE BIDDER

S.r No.	Description of Item	No.	L	B	H	Quantity	Unit
1	Structural steel work riveted, bolted or welded in built up sections, trusses and framed work, including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer all complete.						
	A) Ms angle (40x40x6)mm						
	for frame						
	Top & bottom	2	3.00			6	
	sides	2	2.10			4.2	
	for support	2	2.62			5.24	
	Total length					15.44	
	Total weight @3.57 kg/m					55.12	kg
	B) MS Girder (100 x 50 x 8)mm						
		2	4.73			9.46	
	Total length					9.46	
	Total weight @11.55 kg/m					109.26	kg
	Total Weight (MS Angle + MS Girder)					164.38	kg






2. ALL THE GOVERNMENT/MUNICIPAL CLEARANCE FOR SITC OF THE PRODUCT WILL COME UNDER THE SCOPE OF BIDDER.
3. All the firms participating the Bid No. GEM/2024/B/5192289 are requested to go through clarifications given to each query in the pre-bid from various vendors as mailed to us and modifications made in the Bid.
4. The clarification and amendments made as above is part and parcel of the Bid No. GEM/2024/B/5192289 and would be utilized for the technical & commercial evaluation of the Bid.
5. The bid closing date & time is : 27/08/2024 at 1100 AM

[Handwritten signature]

front.
→



Rev

DP